
# Site Plans

**Zoning Permit Application** Issued for Date Issued Sept. 8, 2020

Latest Issue

Blackrock Riverside Avenue Senior Apartments

356 Riverside Avenue Burlington, Vermont





| Sheet Index |   |                   |
|-------------|---|-------------------|
| No.         | Drawing Title                                   | Latest Issue      |
| C-1.10      | Existing Conditions Plan                        | September 8, 2020 |
| C-2.10      | Site Plan                                       | September 8, 2020 |
| C-3.10      | Grading and Drainage Plan                       | September 8, 2020 |
| C-4.10      | Utility Plan                                    | September 8, 2020 |
| C-4.20      | Utility Profiles                                | September 8, 2020 |
| C-5.10      | Erosion Prevention & Sediment Control Plan      | September 8, 2020 |
| C-6.10      | Site Details                                    | September 8, 2020 |
| C-6.20      | Stormwater Details                              | September 8, 2020 |
| C-6.30      | Erosion Prevention and Sediment Control Details | September 8, 2020 |
| C-6.40      | Water and Wastewater Details                    | September 8, 2020 |
| LA-1.00     | Overall Planting Plan                           | September 8, 2020 |
| LA-1.10     | Planting Plan                                   | September 8, 2020 |
| LA-1.20     | Planting Plan                                   | September 8, 2020 |
| LA-2.00     | Lighting Plan                                   | September 8, 2020 |
| SW-1.10     | Stormwater Management & Maintenance Plan        | September 8, 2020 |


| Reference Index |   |                |
|-----------------|---|----------------|
| No.             | Drawing Title                           | Latest Issue   |
| D-1             | City of Burlington Water System Details | March 20, 2017 |

40 IDX Dr

802.497.6100

Building 100 Suite 200

South Burlington, VT 05403



# Blackrock Riverside Avenue Senior Apartments

356 Riverside Ave Burlington, Vermont

| Designed by | Checked by |
|-------------|------------|
|             |            |
|             |            |
|             |            |
|             |            |
|             |            |

Not Approved for Construction

Existing Conditions
Plan

———

GUARD RAIL

TREE LINE

——○——○— CHAIN LINK FENCE

DRAINAGE LINE
OHW OVERHEAD WIRE

Katherine T and Douglas G Boyden

SPAN: 11403514172 Parcel ID: 040-4-002-000

SPAN: 11403514173 Parcel ID: 040-4-003.000

SPAN: 11403514176 Parcel ID: 040-4-006.000

SPAN: 11403514178 Parcel ID: 040-4-008.000

Moretown, VT 05660

Drawing Number

C-1.10

Sheet of

Project Number

Project Number 58036.00


20 0 20 40 SCALE IN FEET NOTE:
THE LOCATIONS, SIZES, AND TYPES OF EXISTING UTILITIES ARE SHOWN AS AN APPROXIMATE
REPRESENTATION ONLY. THE OWNER OR ITS REPRESENTATIVE(S) HAVE NOT INDEPENDENTLY VERIFIED
THIS INFORMATION AS SHOWN ON THE PLANS. THE UTILITY INFORMATION SHOWN DOES NOT
GUARANTEE THE ACTUAL EXISTENCE, SERVICEABILITY, OR OTHER DATA CONCERNING THE UTILITIES,
NOR DOES IT GUARANTEE AGAINST THE POSSIBILITY THAT ADDITIONAL UTILITIES MAY BE PRESENT THAT
ARE NOT SHOWN ON THE PLANS.



Building 100 Suite 200

802.497.6100

South Burlington, VT 05403



# Blackrock Riverside Avenue Senior Apartments

356 Riverside Ave Burlington, Vermont

| d by | Checked b |
|------|-----------|

Issued for Date

Zoning Permit September 8, 2020

Not Approved for Construction

Site Plan



C 1

Sheet of

Project Number 58036.00

17.4' CONCRETE SIDEWALK -FLUSH CURB -FENCE -SCREENED DUMPSTER STORAGE — REDI-ROCK STYLE RETAINING WALL W/ RAILING \_\_ REDI-ROCK STYLE RETAINING WALL PROPOSED SIDEWALK, TIE TO EXISTING EXISTING DRIVEWAY ACCESS TO REMAIN -BEGIN PROPOSED ASPHALT PAVEMENT WHERE EXISTING DRIVEWAY TURNS TO GRAVEL LIMIT OF WORK -REDI-ROCK STYLE RETAINING WALL 9 AT-GRADE PARKING

w/ CONCRETE PAVEMENT

(BUILDING ABOVE) PROPERTY LINE BUILDING SUPPORT PILLARS (TYP) – PROPOSED BIKE PARKING — **Zoning Summary Chart** Zoning District(S): Neighborhood Activity Center - Riverside Design Review Overlay District(S): Zoning Regulation Requirements Existing Required Proposed 38,882 SF 38,882 SF 29.6% 79.8% LOT COVERAGE

RIVERSIDE AVENUE

21.3'

PROPOSED STEPS TO EXISTING SIDEWALK –

CONCRETE SIDEWALK —


OVERHEAD DOOR -

Parking Summary Chart

Spaces

Existing Proposed

DescriptionExistingProposedPARKING SPACESN/A55STANDARD ACCESSIBLE SPACESN/A1STANDARD ACCESSIBLE VAN SPACESN/A1TOTAL SPACESN/A57






South Burlington, VT 05403

802.497.6100





Riverside Avenue **Senior Apartments** 

356 Riverside Ave Burlington, Vermont

September 8, 2020 **Zoning Permit** 


Not Approved for Construction

**Grading and** Drainage Plan

C-3.10



40 IDX Dr Building 100 Suite 200 South Burlington, VT 05403 802.497.6100





# Riverside Avenue Senior Apartments

356 Riverside Ave Burlington, Vermont

| ed by | Checked by |
|-------|------------|


Issued for Date

Zoning Permit September 8, 2020

Not Approved for Construction

CONSERVATION (VTDEC), VTDEC WASTEWATER SYSTEM AND POTABLE WATER SUPPLY RULES (EPR CHAPT. 1, "WATER/WASTEWATER RULES"), VTDEC WATER SUPPLY RULE (EPR CHAPT 21), AND FOR WORK WITHIN 10 FEET OF THE BUILDING (OR AS APPLICABLE) THE

VERMONT PLUMBING CODE, LATEST EDITIONS.




Drawing Number


C4.10


5 16


South Burlington, VT 05403

802.497.6100









# Blackrock Riverside Avenue **Senior Apartments**

356 Riverside Ave Burlington, Vermont

| Designed by | Checked by |
|-------------|------------|
|             |            |

**Zoning Permit** September 8, 2020

Not Approved for Construction



58036.00


**UTILITY NOTES:** 

1. EXISTING UTILITIES SHALL BE TERMINATED, UNLESS OTHERWISE NOTED, IN CONFORMANCE WITH LOCAL, STATE AND INDIVIDUAL UTILITY COMPANY STANDARD SPECIFICATIONS AND DETAILS. THE CONTRACTOR SHALL COORDINATE UTILITY SERVICE DISCONNECTS WITH THE UTILITY REPRESENTATIVES.


2. ALL WATER AND WASTEWATER WORK SHALL CONFORM WITH THE PROJECT SPECIFIC WATER AND WASTEWATER PERMIT ISSUED BY THE VERMONT DEPARTMENT OF CONSERVATION (VTDEC), VTDEC WASTEWATER SYSTEM AND POTABLE WATER SUPPLY RULES (EPR CHAPT. 1, "WATER/WASTEWATER RULES"), VTDEC WATER SUPPLY RULE (EPR CHAPT 21), AND FOR WORK WITHIN 10 FEET OF THE BUILDING (OR AS APPLICABLE) THE VERMONT PLUMBING CODE, LATEST EDITIONS.



40 IDX Dr Building 100 Suite 200 South Burlington, VT 05403 802.497.6100







356 Riverside Ave Burlington, Vermont

| ned by | Checked by |
|--------|------------|
|        |            |

Zoning Permit

 SILT FENCE OR OTHER APPROVED SILT BARRIER SHALL BE INSTALLED AT THE DOWNSLOPE PERIMETER OF ALL SOILS STOCKPILES.

8. THE CONTRACTOR SHALL TAKE ALL REASONABLE MEANS NECESSARY TO KEEP

THE NEW STORMWATER SYSTEM FREE OF SEDIMENT AND DEBRIS DURING THE CONSTRUCTION PERIOD. DO NOT ALLOW RUNOFF FROM DISTURBED AREAS TO DRAIN THESE FEATURES UNTIL THEY HAVE RECEIVED FINAL STABILIZATION.

Not Approved for Construction

Erosion Prevention and Sediment Control Plan

Draw

C6.10

September 8, 2020


7

40 IDX Dr

802.497.6100


Building 100 Suite 200

South Burlington, VT 05403



- 1. SEGMENTAL WALL IS COMPOSED OF REDI-ROCK WALL "LEDGESTONE" STYLE PRECAST CONCRETE
- UNITS WITH A "NEW ENGLAND LEDGESTONE" COLOR, OR SIMILAR AS APPROVED BY OWNER.
- 2. THIS SECTION IS FOR REFERENCE ONLY. ADDITIONAL DETAILS AND ENGINEERING MAY BE REQUIRED PRIOR TO CONSTRUCTION.
- 3. CONTRACTOR MAY SUBSTITUTE SIMILAR PRODUCTS WITH OWNER PRIOR APPROVAL.

## **Redi-Rock Style Retaining Wall**




CURB -

6" REVEAL

**NOTES** 


FINISH PAVEMENT -

- 1. ALL DIMENSIONS TO EDGES OF 4" PAVEMENT STRIPING.
- 2. 8' STALL WIDTH REFERS TO 8' CLEAR BETWEEN INSIDE EDGES OF PAVEMENT MARKINGS.
- 3. ALL SLOPES THROUGHOUT THE ACCESSIBLE PARKING AND AISLE AREAS SHALL NOT EXCEED 1.5%.



- ROUNDED CONCRETE CAP

CONCRETE FILL



**Accessible Parking Space** N.T.S. LD\_552

- 5" CEMENT CONCRETE

(8" THICK IN VEHICULAR AREAS)

CONCRETE FOR SIDEWALKS TO BE

- COMPACTED EXPANSION

CONCRETE

SIDEWALK -

BLDG. FACE,

FIXED OBJECT,

½" PREFORMED

**EXPANSION JOINT** 

JOINT SEALANT —

OR CONC. SIDEWALK SECTION —

**EXPANSION JOINT DETAIL** 

SUBGRADE

5000 PSI. BOTH MIXES TO BE TYPE II,

GRADE

4000 PSI AND FOR DRIVEWAYS

6% (1.5±) AIR ENTRAINED.

VARIES

1.5% (MAX.)

8" COMPACTED GRAVEL

1. CONCRETE FOR SIDEWALKS TO BE 4000 PSI

2. PROVIDE EXPANSION JOINTS AT MIN. 30 FT.

O.C. WITH PRE- FORMED EXPANSION JOINT

3. PROVIDE TOOLED CONTROL JOINTS AT 6' O.C.

4. PROVIDE BROOM FINISH IN DIRECTION


PERPENDICULAR TO CURB.

TYPE II, 6% (1.5±) AIR ENTRAINED.

FILLER & SEALER.

(VAOT 704.05A) —


**Bollard** LD\_700 N.T.S. Source: VHB




### NOTES

- 1. THE MAXIMUM ALLOWABLE SIDEWALK AND CURB RAMP CROSS SLOPES SHALL BE 1.5 (1% MIN.).
- 2. THE MAXIMUM ALLOWABLE SLOPE OF ACCESSIBLE ROUTE EXCLUDING CURB RAMPS SHALL BE 5%.
- 3. THE MAXIMUM ALLOWABLE SLOPE OF ACCESSIBLE ROUTE AT CURB RAMPS SHALL BE 7.5%. 4. A MINIMUM OF 3 FEET CLEAR SHALL BE MAINTAINED AT ANY PERMANENT OBSTACLE IN ACCESSIBLE ROUTE (I.E., HYDRANTS, UTILITY POLES, TREE WELLS, SIGNS, ETC.).
- 5. CURB TREATMENT VARIES, SEE PLANS FOR CURB TYPE.
- 6. RAMP, CURB AND ADJACENT PAVEMENTS SHALL BE GRADED TO PREVENT PONDING.
- 7. SEE TYPICAL SIDEWALK SECTION FOR RAMP CONSTRUCTION.
- 8. WHERE ACCESSIBLE ROUTES ARE LESS THAN 5' IN WIDTH (EXCLUDING CURBING) A 5' x 5' PASSING AREA SHALL BE PROVIDED AT INTERVALS NOT TO EXCEED 200 FEET.
- 9. ELIMINATE CURBING AT RAMP WHERE IT ABUTS ROADWAY, EXCEPT WHERE VERTICAL CURBING IS INDICATED ON THE DRAWINGS TO BE INSTALLED AND SET FLUSH.
- 10. DETECTABLE WARNINGS SHALL CONTRAST VISUALLY WITH ADJOINING SURFACES.
- 11. DETECTABLE WARNINGS SHALL BE INSTALLED PERPENDICULAR TO THE ACCESSIBLE ROUTE.
- 12. CONTRACTOR TO SUBMIT R.F.I. FOR THIS TYPE OF ACCESSIBLE CURB RAMP FOR APEX ROADWAY CROSSINGS

**Accessible Curb Ramp (ACR) - Type 'B-D'** Source: VHB LD\_501 **Standard Duty Flexible Pavement** 4/18 N.T.S. Source: VHB





# Blackrock Riverside Avenue **Senior Apartments**

356 Riverside Ave **Burlington, Vermont** 

| TAS/CHS       | Checked by JRZ    |
|---------------|-------------------|
| ssued for     | Date              |
| Zoning Permit | September 8, 2020 |
|               |                   |

**Not Approved for Construction** 



**Transition and End Curbs** 2/17 N.T.S. Source: VHB

58036.00

Cast-In-Place Concrete Curb (CC) & Sidewalk Source: VHB LD\_420

# GEOTEXTILE FILTER FABRIC PVC PERFORATED PIPE (SLOPE TO DRAIN) 4" LOAM 8" 18" SAND 18" SAND 5UBGRADE ½ CRUSHED STONE

PAVED AREA SEE APPLICABLE PAVEMENT SECTION LANDSCAPED AREA - COMMON FILL/ ORDINARY BORROW COMPACTED GRANULAR FILL — SAWCUT -DEPTH AND SURFACE TREATMENT VARIES - WARNING TAPE - SAND BLANKET, VAOT ITEM 703.03A HAND TAMPED HAUNCHING - COMPACTED BEDDING - COMPACTED SUBGRADE - ¾" CRUSHED STONE, VAOT ITEM 704.02B **NOTES** 


- 1. WHERE UTILITY TRENCHES ARE CONSTRUCTED THROUGH DETENTION BASIN BERMS OR OTHER SUCH SPECIAL SECTIONS, PLACE TRENCH BACKFILL WITH MATERIALS SIMILAR TO THE SPECIAL SECTION REQUIREMENTS.
- 2. USE METALLIC TRACING/WARNING TAPE OVER ALL PIPES.
- 3. BEDDING TO PROVIDE A FIRM, STABLE, CONTINUOUS, AND UNIFORM SUPPORT FOR THE FULL LENGTH OF THE PIPE.
- 4. NO MECHANICAL TAMPERS SHALL BE USED DIRECTLY OVER THE PIPE TO ENSURE PIPE IS NOT DAMAGED


Storm Drain and Foundation Drain1/16N.T.S.Source: VHBLD\_

### OTES


- 1. STONE WILL BE PLACED ON A FILTER FABRIC FOUNDATION TO THE LINES, GRADES AND LOCATIONS SHOWN IN THE PLAN USING A WELL GRADED STONE MATRIX 2 TO 9 INCHES IN SIZE.
- 2. SET SPACING OF CHECK DAMS AS INDICATED ON PLANS.
- 3. EXTEND THE STONE A MINIMUM OF 1.5 FEET BEYOND THE DITCH BANKS TO PREVENT CUTTING AROUND THE DAM.
- 4. PROTECT THE CHANNEL DOWNSTREAM OF THE LOWEST CHECK DAM FROM SCOUR AND EROSION WITH STONE OR LINER AS APPROPRIATE.
- 5. ENSURE THAT CHANNEL APPURTENANCES SUCH AS CULVERT ENTRANCES BELOW CHECK DAMS ARE NOT SUBJECT TO DAMAGE OR BLOCKAGE FROM DISPLACED STONE.

| <b>Stone Check Dam</b> |             | 08/16 |
|------------------------|-------------|-------|
| N.T.S.                 | Source: VHB | LD_VT |










| Catch Basin (CB) |             |     | 1/16   |
|------------------|-------------|-----|--------|
| N.T.S.           | Source: VHB | REV | LD_101 |



# Drain Manhole (DMH)1/16N.T.S.Source: VHBLD\_115

# Blackrock Riverside Avenue Senior Apartments

40 IDX Dr

802.497.6100

Building 100 Suite 200

South Burlington, VT 05403

356 Riverside Ave Burlington, Vermont

| TAS/CHS               | Checked by JRZ    |  |
|-----------------------|-------------------|--|
| ssued for             | Date              |  |
| Zoning Permit         | September 8, 2020 |  |
| Not Approved for Cons | truction          |  |
| Stormwater Details    |                   |  |


C-6.20

9 16

Project Number 58036.00


ember 8, 2020 6:07:37 PM CHALE-SILLS Plotted Tuesday, September 8, 2020 6:46:16 PM Hale-Sills, Chris

ect Number



- 1. FIBER ROLL SHALL BE PLACED IN SHALLOW TRENCH UP TO 4", WHERE FEASIBLE, PLACING SOIL REMOVED FROM TRENCH BEHIND THE ROLL.
- 2. FIBER ROLLS SHALL BE ANCHORED WITH 2" BY 2" WOODEN STAKES (36" LONG), OR SIMILAR, WHERE FEASIBLE, EITHER INSTALLED THROUGH CENTER OF ROLL (AS SHOWN) OR PLACED ON BOTH SIDES OF ROLL.
- 3. STAKES TO BE PLACED 4 FT APART, MINIMUM.
- 4. SINGLE OR DOUBLE STACKED STAKED FIBER ROLLS TO BE INSTALLED WHERE SOIL DEPTH ALLOWS. WHERE SHALLOW TO BEDROCK, PYRAMID FIBER ROLLS TO BE UTILIZED WITH STAKES, AS FEASIBLE.
- 5. FIBER ROLLS TO BE REPLACED OR REPLENISHED AS NEEDED DURING ACTIVE EARTH WORK.
- 6. PERIMETER CONTROLS SHALL NOT CROSS ACTIVE ACCESS ROUTES (E.G., ROADS) OR ACTIVE FLOW PATHS (E.G., STREAMS/RIVERS).
- 7. PERIMETER CONTROLS SHALL REMAIN IN PLACE AND BE MAINTAINED/REPLACED AS NEEDED UNTIL FINAL STABILIZATION IN AREA HAS BEEN ACHIEVED.

| <b>Staked Fiber Roll</b> |             | 08/16 |
|--------------------------|-------------|-------|
| N.T.S.                   | Source: VHB | LD VT |



- 1. SILT FENCE SHALL BE INSTALLED IN SHORTER RUNS WITH "J-HOOKS" TO AVOID CONCENTRATION OF FLOWS AT ONE LOCATION BY TRAPPING RUNOFF AT MULTIPLE POINTS ALONG A SLOPE.
- 2. MINIMUM WIDTH OF J-HOOK RECOMMENDED AT 20 FT WITH A DEPTH OF 10 FT. WHERE SPACE IS LIMITED (E.G., ALONG NARROW RIGHTS OF WAY), NARROWER HOOKS CAN BE USED WITH A HIGHER SPACING FREQUENCY.
- 3. START DOWN-GRADIENT SILT FENCE LINE AS CLOSE AS POSSIBLE TO UP-GRADIENT J-HOOK.

| <b>Installation</b> | of "J-Hooks" on Slopes | 08/16 |
|---------------------|------------------------|-------|
| N.T.S.              | Source: VHB            | LD_VT |

**PLAN VIEW** 

50' (MIN.)

8" (MIN.) -

**CROSS-SECTION** 

1. AGGREGATE SIZE: USE A MATRIX OF 1 TO 4 INCH STONE, OR RECLAIMED OR RECYCLED CONCRETE

2. LENGTH: NOT LESS THAN 50 FEET (EXCEPT ON SINGLE RESIDENCE LOT WHERE A 30 FOOT MINIMUM

4. WIDTH: TWELVE (12) FOOT MINIMUM, BUT NOT LESS THAN THE FULL WIDTH AT POINTS WHERE

6. ALL SURFACE WATER FLOWING OR DIVERTED TOWARD CONSTRUCTION EXITS SHALL BE PIPED BENEATH THE EXIT. IF PIPING IS IMPRACTICAL, A MOUNTABLE BERM WITH 5:1 SLOPES WILL BE

7. THE EXIT SHALL BE MAINTAINED IN A CONDITION WHICH WILL PREVENT TRACKING OR FLOWING

9. PERIODIC INSPECTION AND NEEDED MAINTENANCE SHALL BE PROVIDED ACCORDING TO PERMIT

8. WHEN WASHING IS REQUIRED IT SHALL BE DONE ON AN AREA STABILIZED WITH STONE AND

OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY, ALL SEDIMENT SPILLED, DROPPED, WASHED OR

5. GEOTEXTILE MUST BE PLACED OVER THE ENTIRE AREA PRIOR TO PLACING OF STONE

TRACKED ONTO PUBLIC RIGHTS-OF-WAY MUST BE REMOVED IMMEDIATELY.

WHICH DRAINS INTO AN APPROVED SEDIMENT TRAPPING DEVICE.

INGRESS OR EGRESS OCCURS. TWENTY-FOUR (24) FOOT MINIMUM IF THERE IS ONLY ONE ACCESS

FILTER

3. THICKNESS: NOT LESS THAN EIGHT (8) INCHES

<u>NOTES</u>

FABRIC —

1½" CRUSHED STONE —

EXISTENCE


PAVEMENT

– MOUNTABLE BERM

– EXISTING


PAVEMENT

1/16



- 1. WOVEN WIRE FENCE REINFORCEMENT IS REQUIRED WITHIN 50 FT UPSLOPE OF RECEIVING WATERS.
- 2. WHERE REQUIRED FENCE SHALL BE WOVEN WIRE, MIN. 14 GAUGE WITH A 6" MESH OPENING SHALL BE
- 3. FILTER CLOTH SHALL BE EITHER FILTER X, MIRAFI 100X, STABILINKA T140N OR APPROVED EQUIVALENT.
- 4. POST SPACING FOR WIRE BACKED FENCE SHALL BE 10 FT. MAX. FOR FILTER CLOTH FENCE WHEN ELONGATION IS >50%, POST SPACING SHALL NOT EXCEED 4 FT. FOR FILTER CLOTH FENCE WHEN ELONGATION IS <50%, POST SPACING SHALL NOT EXCEED 6 FT.
- 5. WHEN TWO SECTIONS OF FILTER CLOTH ADJOIN EACH OTHER THEY SHALL BE OVER-LAPPED BY 6 INCHES
- 6. PREFABRICATED UNITS SHALL BE GEOFAB, ENVIROFENCE OR APPROVED EQUIVALENT.
- 7. MAINTENANCE SHALL BE PERFORMED AS NEEDED AND MATERIAL REMOVED WHEN SEDIMENT REACHES
- 8. SILT FENCE SHALL NOT BE USED TO DEMARCATE LIMITS OF DISTURBANCE.

| Silt Fence/ Reinforced Silt Fence Barrier |             | 08/16     |
|---|-------------|-----------|
| N.T.S.                                    | Source: VHB | LD_650-VT |



- 1. BARRIER MESH TAPE OR ROPE SHALL BE INSTALLED ALONG THE PERIMETER OF THE PROJECT AREA TO DEMARCATE THE LIMIT OF DISTURBANCE. NO EARTHWORK OR STORAGE OF MATERIALS SHALL BE CONDUCTED BEYOND THIS LIMIT WITHOUT PRIOR APPROVAL FROM THE
- 2. USE 3" ORANGE BARRIER MESH TAPE OR 1/2" YELLOW POLYPROPYLENE
- 3. WITHIN 50' OF WATER RESOURCE AREAS, USE 2-3 ROWS OF TAPE OR ROPE. BEYOND 50' OF WATER RESOURCE AREAS USE 1 ROW OF TAPE OR
- 4. TAPE OR ROPE MAY BE FASTENED TO STAKES, TREES, OR OTHER APPROPRIATE FIXED OBJECTS.
- 5. PROJECT DEMARCATION SHALL NOT CROSS ACTIVE ACCESS ROUTES (E.G. ROADS). PROJECT DEMARCATION MAY CROSS RESOURCES AREAS WITH EXCEPTION OF LARGER WATER BODIES WHERE IT IS NOT FEASIBLE OR ADVISABLE.
- 6. PROJECT DEMARCATION SHALL REMAIN IN PLACE AND BE MAINTAINED/REPLACED AS NEEDED UNTIL FINAL STABILIZATION IN THE AREA HAS BEEN ACHIEVED.

| Barrier Mesh Tape or Rope |             | 08/16 |
|---------------------------|-------------|-------|
| N.T.S.                    | Source: VHB | LD_VT |

# Blackrock Riverside Avenue **Senior Apartments**

356 Riverside Ave **Burlington, Vermont** 

| . Revision   | Date App         |
|--------------|------------------|
|              |                  |
|              |                  |
|              |                  |
|              |                  |
|              |                  |
|              |                  |
| TAZ/CHS      | Checked by JRZ   |
| ued for      | Date             |
| onina Permit | September 8, 202 |

40 IDX Dr

802.497.6100

Building 100 Suite 200


South Burlington, VT 05403


**Not Approved for Construction** 

**Erosion Prevention and Sediment Control Details** 

**Stabilized Construction Exit** N.T.S. Source: VHB LD\_682-VT


58036.00





### WATER & SANITARY UTILITY CROSSINGS

| Water/Sewer Separation |             | 1/* |
|------------------------|-------------|-----|
| N.T.S.                 | Source: VHB | L   |



40 IDX Dr Building 100 Suite 200 South Burlington, VT 05403 802.497.6100

5. MATCH EXISTING PAVEMENT AND SUBBASE DEPTH IN CITY ROW

Waterline Trench

N.T.S. Source: VHB LD\_

2. USE METALLIC TRACING/WARNING TAPE OVER ALL PIPES.


3. BEDDING TO PROVIDE A FIRM, STABLE, CONTINUOUS, AND

UNIFORM SUPPORT FOR THE FULL LENGTH OF THE PIPE.

4. NO MECHANICAL TAMPERS SHALL BE USED DIRECTLY OVER THE

SPECIAL SECTION REQUIREMENTS.


PIPE TO ENSURE PIPE IS NOT DAMAGED



### **NOTES**

- WET TAPS SHALL BE PERFORMED BY PRE-APPROVED FIRMS
- 2. ALL FITTINGS THAT ARE TO HAVE CONCRETE POURED AROUND THEM ARE TO BE WRAPPED WITH 4 MIL. POLYETHYLENE PRIOR TO CONCRETE PLACEMENT
- 3. REFER TO REFERENCE DRAWING D1 "BURLINGTON DEPARTMENT OF PUBLIC WORKS WATER SYSTEM DETAILS"

| Typical Tapping Sleeve and Valve Detail |             | 2/18 |     |
|---|-------------|------|-----|
| N.T.S.                                  | Source: VHB | REV  | LD_ |



NO MECHANICAL TAMPERS SHALL BE USED DIRECTLY OVER THE PIPE TO ENSURE PIPE IS NOT DAMAGED
 MATCH EXISTING PAVEMENT AND SUBBASE DEPTH IN CITY ROW

Source: VHB

**Sewerline Trench** 

N.T.S.

# Blackrock Riverside Avenue Senior Apartments

356 Riverside Ave Burlington, Vermont

| No. Revision  | Date       | Appvd  |
|---------------|------------|--------|
|               |            |        |
|               |            |        |
|               |            |        |
|               |            |        |
|               |            |        |
|               |            |        |
|               |            |        |
|               |            |        |
| Designed by   | Checked by |        |
| TAZ/CHS       |            | JRZ    |
| issued for    | Date       |        |
| Zanina Darmit | September  | 8 2020 |
| Zoning Permit | September  | o, 202 |

Not Approved for Construction


Water and
Wastewater
Details

1/16

Drawing Numb

C-6.40

11 16



### DI ANT SCHEDI II E

| PLANT SCHED     | ULE           |   |                                 |                 |
|-----------------|---------------|---|---------------------------------|-----------------|
| DECIDUOUS TREES | QTY           | BOTANICAL NAME                              | COMMON NAME                     | SIZE            |
| AF              | 4             | Acer x freemanii `Sienna`                   | Sienna Glen Maple               | 2 1/2 - 3" CAL. |
| BN              | 3             | Betula nigra `Heritage`                     | Multi-Stem Heritage River Birch | 12 -14` HT.     |
| GT              | 1             | Gleditsia triacanthos inermis 'Shademaster' | Shademaster Locust              | 2 1/2 - 3" CAL. |
| SHRUBS          | QTY           | BOTANICAL NAME                              | COMMON NAME                     | SIZE            |
| CA2             | 11            | Cornus stolonifera `Arctic Fire`            | Arctic Fire Dogwood             | 18 - 24" SPD    |
| MD              | 29            | Microbiota decussata                        | Russian Cypress                 | 18 - 24" SPD    |
| RH              | 39            | Rhus aromatica `Gro-Low`                    | Gro-Low Fragrant Sumac          | 18 - 24" SPD    |
| GRASSES         | QTY           | BOTANICAL NAME                              | COMMON NAME                     | SIZE            |
| DS              | <del>74</del> | Deschampsia cespitosa `Schottland`          | Schottland Hair Grass           | 2 GAL.          |
| PVS             | 21            | Panicum virgatum `Shenandoah`               | Shenendoah Switch Grass         | 2 GAL.          |

### **Tree Protection**

- EXISTING TREES TO REMAIN SHALL BE PROTECTED WITH TEMPORARY CONSTRUCTION FENCE. ERECT FENCE AT EDGE OF THE TREE DRIPLINE PRIOR TO START OF CONSTRUCTION.
- 2. CONTRACTOR SHALL NOT OPERATE VEHICLES WITHIN THE TREE PROTECTION AREA. CONTRACTOR SHALL NOT STORE VEHICLES OR MATERIALS, OR DISPOSE OF ANY WASTE MATERIALS, WITHIN THE TREE PROTECTION AREA.
- DAMAGE TO EXISTING TREES CAUSED BY THE CONTRACTOR SHALL BE REPAIRED BY A CERTIFIED ARBORIST AT THE CONTRACTOR'S EXPENSE.

### **Planting Notes**

- 1. ALL PROPOSED PLANTING LOCATIONS SHALL BE STAKED AS SHOWN ON THE PLANS FOR FIELD REVIEW AND APPROVAL BY THE LANDSCAPE ARCHITECT PRIOR TO INSTALLATION.
- 2. CONTRACTOR SHALL VERIFY LOCATIONS OF ALL BELOW GRADE AND ABOVE GROUND UTILITIES AND NOTIFY OWNERS REPRESENTATIVE OF CONFLICTS.
- 3. NO PLANT MATERIALS SHALL BE INSTALLED UNTIL ALL GRADING AND CONSTRUCTION HAS BEEN COMPLETED IN THE IMMEDIATE AREA. CONTRACTOR SHALL NOTIFY OWNER'S REPRESENTATIVE OF ANY CONFLICT.
- 4. A 3-INCH DEEP MULCH PER SPECIFICATION SHALL BE INSTALLED UNDER ALL TREES AND SHRUBS, AND IN ALL PLANTING BEDS, UNLESS OTHERWISE INDICATED ON THE PLANS, OR AS DIRECTED BY OWNER'S REPRESENTATIVE.
- 5. ALL TREES SHALL BE BALLED AND BURLAPPED, UNLESS OTHERWISE NOTED IN THE DRAWINGS OR SPECIFICATION, OR APPROVED BY THE OWNER'S REPRESENTATIVE.
- 6. FINAL QUANTITY FOR EACH PLANT TYPE SHALL BE AS GRAPHICALLY SHOWN ON THE PLAN. THIS NUMBER SHALL TAKE PRECEDENCE IN CASE OF ANY DISCREPANCY BETWEEN QUANTITIES SHOWN ON THE PLANT LIST AND ON THE PLAN. THE CONTRACTOR SHALL REPORT ANY DISCREPANCIES BETWEEN THE NUMBER OF PLANTS SHOWN ON THE PLANT LIST AND PLANT LABELS PRIOR TO BIDDING.
- 7. ANY PROPOSED PLANT SUBSTITUTIONS MUST BE REVIEWED BY LANDSCAPE ARCHITECT AND APPROVED IN WRITING BY THE OWNER'S REPRESENTATIVE.
- 8. ALL PLANT MATERIALS INSTALLED SHALL MEET THE SPECIFICATIONS OF THE "AMERICAN STANDARDS FOR NURSERY STOCK" BY THE AMERICAN ASSOCIATION OF NURSERYMEN AND CONTRACT DOCUMENTS.
- 9. ALL PLANT MATERIALS SHALL BE GUARANTEED FOR ONE YEAR FOLLOWING DATE OF FINAL ACCEPTANCE.
- 10. AREAS DESIGNATED "LOAM & SEED" SHALL RECEIVE MINIMUM 6" OF LOAM AND SPECIFIED SEED MIX. LAWNS OVER 2:1 SLOPE SHALL BE PROTECTED
- 11. ALL DISTURBED AREAS NOT OTHERWISE NOTED ON CONTRACT DOCUMENTS SHALL BE LOAM AND SEEDED OR MULCHED AS DIRECTED BY OWNER'S
- 12. THIS PLAN IS INTENDED FOR PLANTING PURPOSES. REFER TO SITE / CIVIL DRAWINGS FOR ALL OTHER SITE CONSTRUCTION INFORMATION.

### **Plant Maintenance Notes**

WITH EROSION CONTROL FABRIC.

- 1. CONTRACTOR SHALL PROVIDE COMPLETE MAINTENANCE OF THE LAWNS AND PLANTINGS. NO IRRIGATION IS PROPOSED FOR THIS SITE. THE CONTRACTOR SHALL SUPPLY SUPPLEMENTAL WATERING FOR NEW LAWNS AND PLANTINGS DURING THE ONE YEAR PLANT GUARANTEE PERIOD.
- 2. CONTRACTOR SHALL PROVIDE ALL MATERIALS, LABOR, AND EQUIPMENT FOR THE COMPLETE LANDSCAPE MAINTENANCE WORK. WATER SHALL BE PROVIDED BY THE CONTRACTOR.
- 3. WATERING SHALL BE REQUIRED DURING THE GROWING SEASON, WHEN NATURAL RAINFALL IS BELOW ONE INCH PER WEEK.
- 4. WATER SHALL BE APPLIED IN SUFFICIENT QUANTITY TO THOROUGHLY SATURATE THE SOIL IN THE ROOT ZONE OF EACH PLANT.
- 5. CONTRACTOR SHALL REPLACE DEAD OR DYING PLANTS AT THE END OF THE ONE YEAR GUARANTEE PERIOD. CONTRACTOR SHALL TURN OVER MAINTENANCE TO THE FACILITY MAINTENANCE STAFF AT THAT TIME.



40 IDX Dr

South Burlington, VT 05403 802.497.6100

Building 100 Suite 200





356 Riverside Ave Burlington, Vermont

| Designed by MW | Checked by MW     |
|----------------|-------------------|
| Issued for     | Date              |
| Zoning Permit  | September 8, 2020 |
|                |                   |

Not Approved for Construction



LA-1.00


**12** 



Building 100 Suite 200

802.497.6100

South Burlington, VT 05403



Blackrock

# Riverside Avenue **Senior Apartments**

| Revision | Date       | Appvd. |
|----------|------------|--------|
|          |            |        |
|          |            |        |
|          |            |        |
|          |            |        |
|          |            |        |
|          |            |        |
|          |            |        |
|          |            |        |
|          |            |        |
| igned by | Checked by |        |

September 8, 2020


**Planting Plan** 


LA-1.10

of 13 16



40 IDX Dr Building 100 Suite 200 South Burlington, VT 05403 802.497.6100





# Blackrock Riverside Avenue Senior Apartments

356 Riverside Ave Burlington, Vermont

| Revision | Date | Appva. |
|----------|------|--------|
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |
|          |      |        |

MW
Issued for Date

Zoning Permit September 8, 2020

ining Permit September

Not Approved for Construction

Drawing Title

Planting Plan

LA-1.20

Sheet of **14 16** 

± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.0 ± 5.1 ± 5.2 ± 5.1 ± 5.0

Blackrock **Riverside Avenue** 

356 Riverside Ave **Burlington, Vermont** 

Building 100 Suite 200

802.497.6100

South Burlington, VT 05403

**Zoning Permit** September 8, 2020

**Not Approved for Construction** 

**Lighting Plan** 

58036.00

15

LIGHT FIXTURE SPECIFICATIONS

Fixture E

Fixture:

Voltage:

Color:

LED:

Manufacturer:

Fixture A Manufacturer: Beacon Lighting Fixture: SRT1 EDGE-LIT Color: Black LED: 35watt - 5QW LED Color: 3,000k Voltage: 120v (verify with electrical engineer)

Philips Lightolier

650Lumen - 3,000k

SlimSurface LED - S5R (5inch)

120v (verify with electrical engineer)

Manufacturer KIM Lighting Compact Bollard - CB32 LED Fixture: Color: LED: 10w LED Color: 3,000k Voltage: 120v (verify with electrical engineer)

Kichler Lighting

Black

3000k

Manhattan 22" Wall Light

120v (verify with electrical engineer)

Fixture B

Fixture F

Fixture:

Voltage:

LED Color:

Color:

Manufacturer:

Manufacturer: Beacon Lighting Products Traverse Wall Light TRV-D Fixture: Black 27watt - Type 3 LED Color: 120v (verify with electrical engineer) Voltage: Mounting: 12 Feet

Color: LED:

LED Color: 3,000k 120v (verify with electrical engineer) Voltage: 16 Feet Pole:

Fixture D

Fixture:

Manufacturer:

39watt - Type 3

Viper S

Black

Beacon Lighting Products

STATISTICAL AREA SUMMARY

Grid Type: Horizontal Illuminance at finish grade. Grid Units: Footcandles Statistical Area Max/Min Parking Lot and Entry Drive 1.73 7.40 0.20 8.65

Fixture C

Color:

LED:


This analysis was calculated in accordance with published IES calculation methods and procedures with the data as entered by the user. This analysis is based on tested IES photometric data, light loss factors as defined in the LLF value. This analysis is a mathematical model of real life situations, and it can be only as accurate as the model itself. Calculated values may vary from actual measurements in certain situations. VHB is not responsible for light output deviations due to light fixture or ballast combinations or other variables.

| STORMWATER MAINTENANCE PLAN |        |                         |   |
|-----------------------------|--------|-------------------------|---|
| STORMWATER<br>SYSTEM        | SYMBOL | INSPECTION<br>FREQUENCY | MAINTENANCE ACTIVITY TRIGGERS AND ACTIONS   |
| CATCH BASIN<br>(DEEP SUMP)  |        |                         | SEDIMENT SHALL BE CLEANED OUT OF CATCH BASIN SUMPS WHEN IT ACCUMULATES TO >50% OF SUMP DEPTH.   |
| ROOF DRAIN                  | •      |                         | ROOF DRAIN INLETS AND OUTLETS SHALL BE KEPT CLEAN OF DEBRIS.  |
| SUBSURFACE<br>STORAGE       |        | ANNUAL                  | INSPECT AND REMOVE DEBRIS FROM OUTLET CONTROL. REMOVE ACCUMULATION OF DEBRIS FROM PIPE CHAMBERS AS NEEDED.  |
| DRY SWALE                   |        |                         | WHEN WATER PONDS IN THE BOTTOM OF THE DRY SWALE FOR MORE THAN 48 HOURS THE TOP FEW INCHES OF MATERIAL SHALL BE REMOVED AND REPLACED WITH CLEAN SAND |


SUBCATCHMENT BOUNDARIES



802.497.6100







# Riverside Avenue Senior Apartments

356 Riverside Ave Burlington, Vermont

TAS/CHS

Zoning Permit September 8, 2020

Not Approved for Construction

Stormwater Management & Maintenance Plan

Drawing Num

SW-1.10

Checked by JRZ

Sheet of **16 1**0